



Declaration of Conformity CE marking  
ETERNIT SAS



The undersigned, representing the following:

Manufacturer	
<b>ETERNIT SAS</b>	
<b>3, rue de l'Amandier - BP 33</b>	
<b>78 540 VERNUILLET</b>	
<b>France</b>	
Manufacturing plant	<b>9003</b>

Following the provisions of the 89/106/EEC Construction Products Directive

Herewith declare that the products, **NEW STONIT SLATES** to which this declaration relates are in conformity with the provisions as described in the annex ZA of the following standard(s) :

EN492:2004

**Fibre-cement slates and fittings – Product specification and test**

Intended use(s) :

- Discontinuously laid roof coverings for buildings
- Internal and external wall and ceiling finishes

Characteristic	Performance declaration	References
Mechanical resistance	Class B	CQ report réf G3-2005
External fire exposure	Deemed to satisfy commission decision (2000/553/EC)	CSTB réf. ES 541-05-0535
Reaction to fire	Class A2 – s1 , d0	CSTB réf. ES 541-05-0535
Water permeability	pass	Redco réf. EHA 02.103 du 04/09/02
Dimensional variations	pass	CQ report réf G3-2005
Release of dangerous substances	Type NT	
Durability against warm water	pass	Redco réf. EHA 02.103 du 04/09/02
Durability against soak / dry	pass	Redco réf. EHA 02.103 du 04/09/02
Durability against freeze-thaw	pass	Redco réf. EHA 02.103 du 04/09/02
Durability against heat-rain	pass	Redco réf. EHA 02.103 du 04/09/02

Name and address of notified laboratory involved :

**Centre Scientifique et Technique du Bâtiment - CSTB**

84 avenue Jean Jaurès – Champs sur Marne BP 02 – F-77421 Marne-la-Vallée Cedex 2

**REDCO - Kuiermanstraat 1 – B-1880 Kapelle-op-den-Bos**

For the manufacturer
Name : <b>Laurent BONGRAND</b>
Position : <b>Managing Director</b>
Date : <b>17<sup>th</sup> November 2005</b>